

## MCB 1P 25kA C-16A 1M

## NRN116

## Architecture

Neutral position	without neutral
Number of protected poles	1
Number of poles	1 P
Type of pole	1 P
Fixing mode	Din-Rail
Curve	С
Compatibility	
Compatible with DIN rail mounting	yes
Controls and indicators	
With fault indicator	no
Connectivity	
Bottom connection alignement for modular devices	Aligned terminal
Top connection alignement for modular devices	Aligned terminal
Main electrical features	
Type of supply voltage	AC
Rated operational voltage Ue	240/415 V
Voltage	
Rated insulation voltage	500 V
Max operating voltage	415 V
Rated impulse withstand voltage	6000 V
Electric current	
Rated short circuit breaking capacity Icn under 230V AC according IEC60898-1	10 kA
Rated short circuit breaking capacity Icn under 240V AC according IEC 60898-1	10 kA
Rated service breaking capacity Ics AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 220V AC according IEC 60947-2	7,5 kA

Technical Properties	
Rated service breaking capacity Ics under 230V AC	7,5 kA
according IEC 60947-2	
Rated service breaking capacity Ics under 240V AC	7,5 kA
according IEC 60947-2	
Breaking capacity on 1 pole with 400 V NF 60947-2	3 kA
Breaking capacity on 1 pole with 415 V NF 60947-2	3 kA
Rated service breaking capacity Ics under 220V AC	7,5 kA
according IEC 60898-1	
Rated service breaking capacity Ics under 230V AC	7,5 kA
according IEC 60898-1	
Rated service breaking capacity Ics under 240V AC	7,5 kA
according IEC 60898-1	
Rated ultimate short-circuit breaking capacity Icu	25 kA
under 220V AC IEC 60947-2	
Rated ultimate short-circuit breaking capacity Icu	25 kA
under 230V AC IEC 60947-2	
Rated ultimate short-circuit breaking capacity Icu	25 kA
under 240V AC IEC 60947-2	
Magnetic regulating currrent at 40° C	5/10 ln
min/maxi threshold value of the DC magnetic	5/15 ln
operation	o, 10 III
min/maxi threshold value of the AC thermal operation	1 13/1 45 In
min/maxi threshold value of the DC thermal operation	
min/maxi threshold value of the bothermal operation	1,10,1,40 111
Electric current / temperature	
Rating current 0°C according to IEC 60947-2	21,21 A
Rating current 10°C according to IEC 60947-2	20,28 A
Rating current -10°C according to IEC 60947-2	22,11 A
Rating current 150°C according to IEC 60947-2	19,79 A
Rating current -15°C according to IEC 60947-2	ZZ,34 A
Rating current -15°C according to IEC 60947-2 Rating current 20°C according to IEC 60947-2	22,54 A 19,3 A
Rating current 20°C according to IEC 60947-2	19,3 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2	19,3 A 22,97 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current -5°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current -5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 55°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 15,38 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 15,38 A 14,74 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 15,38 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 15,38 A 14,74 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 15,38 A 14,74 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 15,38 A 14,74 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current -25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current for according to IEC 60947-2	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 70°C according to IEC 60947-2 Current correction factors  Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 55°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 70°C according to IEC 60947-2 Current correction factors  Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 55°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Current correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 55°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Current correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Current correction factors  Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 70°C according to IEC 60947-2 Current correction factors  Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A
Rating current 20°C according to IEC 60947-2 Rating current -20°C according to IEC 60947-2 Rating current 25°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 30°C according to IEC 60947-2 Rating current 35°C according to IEC 60947-2 Rating current 40°C according to IEC 60947-2 Rating current 45°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 5°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 50°C according to IEC 60947-2 Rating current 60°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Rating current 65°C according to IEC 60947-2 Current correction factors  Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side	19,3 A 22,97 A 18,79 A 23,39 A 18,26 A 17,73 A 17,17 A 16,59 A 20,75 A 21,66 A 16 A 15,38 A 14,74 A 14,06 A 13,36 A

Technical Properties	
Correction factor of rating current for 6 devices place	1085
side-by-side	d 0,00
0.00 2, 0.00	
Power	
Power loss per pole at In	2,62 W
Maximum power loss per pole according to the	3,5 W
product standard	
Total power loss under IN	2,62 W
Tripping	
Time of response when opening	7 ms
Endurance	
Endurance	
Electric endurance in number of cycles	4000
Number of mechanical operations	20000
Dimensions	
Depth of installed product	70 mm
Height of installed product	83 mm
Width of installed product	17,5 mm
Installation, mounting	
Type of top connection for modular devices	with screw
Tightening torque	2,8Nm
Type of bottom rail clip for modular devices	plastic
Type of top rail clip for modular devices	NA
Type of Bottom Connection for modular devices	Blconnect
Bottom removability for modular devices	yes
Top removability for modular devices	yes
Suitable for flush-mounting	yes
Connection	
Upstream cage clamp delivery status	opened
Downstream cage clamp delivery status	opened
Connection cross-section at output with screw, for flexible conductor	1/25 mm <sup>2</sup>
Connection cross-section of the access with screws,	1/25 mm²
with flexible conductor	1/23 11111
Connection cross-section at output with screw, for	1/35 mm²
massive conductor	
Connection cross-section for rigid conductor,	1/35 mm²
upstream terminals with screws	
Equipment	
Can be accessorized	yes
	-
Standards	
Standard text	IEC 60947-2
European directive WEEE	concerned
1	

## Safety

Protection index IP	IP20
Use conditions	
Degree of pollution according to IEC 60664 / IEC 60947-2	2
Class of energy limitation I2t	3
Altitude	2000 m
Storage temperature	-25 to 80 °C
Air humidity protection	for all climates
temperatur	
Temperature of calibration	50 °C