Product Data Sheet NCN406A





NCN406A



NCN406A

MCB 4P 10kA C-6A 4M

Technische Merkmale

Neutral position	without neutral
Number of protected poles	4
Number of poles	4 P
Type of pole	4 P
Curve	С
Connectivity	
Bottom connection alignement for modular devices	Aligned terminal
Top connection alignement for modular devices	Aligned terminal
Main electrical features	
Type of supply voltage	AC
·)pe el esppl) · ellege	
Rated operational voltage Ue	415 V
Rated operational voltage Ue	415 V
Rated operational voltage Ue Voltage	415 V 12 V
Rated operational voltage Ue Voltage Minimum threshold voltage (Ue min)	
	12 V

Electric current

min/maxi threshold value of the DC thermal operation	1,13/1,45 In
min/maxi threshold value of the AC thermal operation	1,13/1,45 In
min/maxi threshold value of the DC magnetic operation	7/15 In
Magnetic regulating currrent at 40° C	5/10 In
Rated ultimate short-circuit breaking capacity Icu under 415V AC IEC 60947-2	15 kA
Rated ultimate short-circuit breaking capacity Icu under 380V AC IEC 60947-2	15 kA
Rated ultimate short-circuit breaking capacity Icu under 240V AC IEC 60947-2	30 kA
Rated ultimate short-circuit breaking capacity Icu under 230V AC IEC 60947-2	30 kA
Rated ultimate short-circuit breaking capacity Icu under 220V AC IEC 60947-2	30 kA
Rated service breaking capacity Ics under 415V AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 400V AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 380V AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 240V AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 230V AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 220V AC according IEC 60898-1	7,5 kA
Rated service breaking capacity Ics under 415V AC according IEC 60947-2	7,5 kA
Rated service breaking capacity Ics under 400V AC according IEC 60947-2	7,5 k/
Rated service breaking capacity Ics under 380V AC according IEC 60947-2	7,5 kA
Rated service breaking capacity Ics under 240V AC according IEC 60947-2	15 k/
Rated service breaking capacity Ics under 230V AC according IEC 60947-2	15 kA
Rated service breaking capacity Ics under 220V AC according IEC 60947-2	15 kA
Rated service breaking capacity Ics AC according IEC 60898-1	7,5 k⁄
Rated short circuit breaking capacity Icn under 415V AC according IEC 60898-1	10 kA
Rated short circuit breaking capacity Icn under 380V AC according IEC 60898-1	10 k/
Rated short circuit breaking capacity Icn under 240V AC according IEC 60898-1	10 k/
Rated short circuit breaking capacity Icn under 400V AC according IEC60898-1	10 k/
Rated short circuit breaking capacity Icn under 230V AC according IEC60898-1	10 k/
Rated ultimate short-circuit breaking capacity Icu under 400V AC IEC 60947-2	15 k/

:hager

Rating current 0°C 6,93 / Rating current 10°C 6,63 / Rating current 10°C 7,21 / Rating current 25°C 6,16 / Rating current 25°C 7,61 / Rating current 30°C 6 / Rating current 30°C 5 / Rating current 30°C 5 / Rating current 35°C 5,61 / Rating current 40°C 5,61 / Rating current 5°C 6 / Rating current 5°C 7,07 / Rating current 5°C 7,07 / Rating current 5°C 7,07 / Rating current 5°C 4,97 / Rating current 6°C 4,54 / Rating current 6°C 4,54 / Rating current 7°C 4,24 / Rating current 7°C 4,24 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 15°C according to IEC 60947-2 7,85 / Rating current 15°C according to IEC 60947-2 7,85 / Rating current 15°C according to IEC 60947-2 8,33 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current 25°C according to IEC 60947-2 8,63 / <t< th=""><th>Rating current -15°C</th><th>7,35 A</th></t<>	Rating current -15°C	7,35 A
Rating current 10°C 6,63 Rating current -10°C 7,21 Rating current 25°C 6,16 Rating current 25°C 7,61 Rating current 30°C 6 Rating current 35°C 5,81 Rating current 45°C 5,61 Rating current 45°C 5,61 Rating current 45°C 6,78 Rating current 45°C 6,78 Rating current 5°C 7,07 Rating current 5°C 7,07 Rating current 5°C 7,07 Rating current 5°C 4,97 Rating current 0°C 4,24 Rating current 0°C 4,24 Rating current 1°C according to IEC 60947-2 7,52 Rating current 1°C according to IEC 60947-2 7,52 Rating current 1°C according to IEC 60947-2 7,17 Rating current 1°C according to IEC 60947-2 8,33 Rating current 1°C according to IEC 60947-2 8,33 Rating current 1°C according to IEC 60947-2 <t< td=""><td>Rating current -20°C</td><td>7,48 A</td></t<>	Rating current -20°C	7,48 A
Rating current 10°C 7,21 / Rating current 25°C 6,16 / Rating current 25°C 7,61 / Rating current 30°C 6 / Rating current 35°C 5,81 / Rating current 35°C 5,81 / Rating current 40°C 5,61 / Rating current 45°C 5,81 / Rating current 5°C 6,78 / Rating current 5°C 7,07 / Rating current 5°C 7,07 / Rating current 5°C 4,97 / Rating current 5°C 4,57 / Rating current 10°C 4,24 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 8,33 / Rating current 10°C according to IEC 60947-2 8,33 / Rating current 10°C according to IEC 60947-2	Rating current 0°C	6,93 A
Rating current 25°C 6,16 / Rating current 25°C 7,61 / Rating current 30°C 6 / Rating current 30°C 5,81 / Rating current 40°C 5,61 / Rating current 45°C 5,81 / Rating current 5°C 6,78 / Rating current 5°C 6,78 / Rating current 5°C 7,07 / Rating current 5°C 4,97 / Rating current 5°C 4,97 / Rating current 70°C 4,24 / Rating current 70°C 4,24 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 20°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,48 / Ra	Rating current 10°C	6,63 A
Rating current -25°C 7,61 / Rating current 30°C 6 / Rating current 35°C 5,81 / Rating current 45°C 5,61 / Rating current 45°C 5,61 / Rating current 5°C 6,78 / Rating current 5°C 6,78 / Rating current 5°C 7,07 / Rating current 5°C 4,97 / Rating current 5°C 4,97 / Rating current 65°C 4,5 / Rating current 1°C 4,24 / Rating current 1°C according to IEC 60947-2 7,85 / Rating current 1°C according to IEC 60947-2 7,85 / Rating current 1°C according to IEC 60947-2 8,33 / Rating current 2°C according to IEC 60947-2 8,33 / Rating current 2°C according to IEC 60947-2 8,48 / Rating current 2°C according to IEC 60947-2 8,63 / Rating current 3°C according to IEC 60947-2 8,63 / Rating current 3°C according to IEC 60947-2 6,61 / <	Rating current -10°C	7,21 A
Rating current 30°C 6 / Rating current 35°C 5,81 / Rating current 40°C 5,61 / Rating current 45°C 5,41 / Rating current 5°C 6,78 / Rating current 5°C 6,78 / Rating current 5°C 6,78 / Rating current 5°C 7,07 / Rating current 5°C 7,07 / Rating current 5°C 4,97 / Rating current 5°C 4,97 / Rating current 6°C 4,74 / Rating current 6°C 4,54 Rating current 6°C 4,54 Rating current 0°C according to IEC 60947-2 7,85 / Rating current 1°C according to IEC 60947-2 7,52 / Rating current 1°C according to IEC 60947-2 7,35 / Rating current 1°C according to IEC 60947-2 8,33 / Rating current 2°C according to IEC 60947-2 8,83 / Rating current 2°C according to IEC 60947-2 8,64 / Rating current 3°C according to IEC 60947-2 8,64 / Rating current 3°C according to IEC 60947-2 8,64 / Rating current 3°C according to IEC 60947-2 6,61 / Rating current 3°C according to IEC 60947-2 6,61 / <td>Rating current 25°C</td> <td>6,16 A</td>	Rating current 25°C	6,16 A
Rating current 35°C 5.81 / Rating current 40°C 5.61 / Rating current 40°C 5.61 / Rating current 45°C 5.61 / Rating current 5°C 6.78 / Rating current 5°C 6.78 / Rating current 5°C 7.07 / Rating current 5°C 7.07 / Rating current 5°C 7.07 / Rating current 5°C 4.97 / Rating current 5°C 4.97 / Rating current 60°C 4.74 / Rating current 65°C 4.5 / Rating current 70°C 4.24 / Rating current 0°C according to IEC 60947-2 7.85 / Rating current 10°C according to IEC 60947-2 7.85 / Rating current 10°C according to IEC 60947-2 7.35 / Rating current 10°C according to IEC 60947-2 7.35 / Rating current 10°C according to IEC 60947-2 8.33 / Rating current 15°C according to IEC 60947-2 8.33 / Rating current 20°C according to IEC 60947-2 8.63 / Rating current 20°C according to IEC 60947-2 8.64 / Rating current 30°C according to IEC 60947-2 6.61 / Rating current 30°C according to IEC 60947-2	Rating current -25°C	7,61 A
Rating current 40°C 5,61 / Rating current 45°C 5,41 / Rating current 5°C 6,78 / Rating current 5°C 7,07 / Rating current 5°C 4,97 / Rating current 5°C 4,97 / Rating current 5°C 4,97 / Rating current 60°C 4,74 / Rating current 65°C 4,57 / Rating current 65°C 4,57 / Rating current 70°C 4,24 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current 35°C according to IEC 60947-2 6,61 / Rating current 35°C according to IEC 60947-2 6,61 / Rating current 45°C according to IEC 60947-2	Rating current 30°C	6 A
Rating current 45°C 5,41 / Rating current 5°C 6,78 / Rating current 5°C 7,07 / Rating current 5°C 7,07 / Rating current 5°C 5,19 / Rating current 5°C 4,97 / Rating current 5°C 4,97 / Rating current 60°C 4,74 / Rating current 66°C 4,5 / Rating current 66°C 4,5 / Rating current 70°C 4,24 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 8,33 / Rating current 15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,61 / Rating current 30°C according to IEC 60947-2 6,61 / Rating current 45°C according to IEC 60947-2 6,61 / <	Rating current 35°C	5,81 A
Rating current 5°C 6,78 Rating current 5°C 7,07 Rating current 5°C 7,07 Rating current 50°C 5,19 Rating current 50°C 4,97 Rating current 60°C 4,74 Rating current 60°C 4,74 Rating current 60°C 4,24 Rating current 70°C 4,24 Rating current 0°C according to IEC 60947-2 7,85 Rating current 10°C according to IEC 60947-2 7,52 Rating current 10°C according to IEC 60947-2 7,35 Rating current 150°C according to IEC 60947-2 7,35 Rating current 150°C according to IEC 60947-2 7,35 Rating current 150°C according to IEC 60947-2 7,37 Rating current 25°C according to IEC 60947-2 8,33 Rating current 25°C according to IEC 60947-2 8,48 Rating current 25°C according to IEC 60947-2 6,61 Rating current 35°C according to IEC 60947-2 6,61 Rating current 45°C according to IEC 60947-2 6,61 Rating current 45°C according to IEC 60947-2 6,61 Rating current 5°C according to IEC 60947-2 6,61 Rating current 45°C according to IEC 60947-2 6,61	Rating current 40°C	5,61 A
Rating current -5°C 7,07 / Rating current 50°C 5,19 / Rating current 55°C 4,97 / Rating current 60°C 4,74 / Rating current 65°C 4,5 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 15°C according to IEC 60947-2 7,35 / Rating current 15°C according to IEC 60947-2 7,35 / Rating current 20°C according to IEC 60947-2 7,35 / Rating current 20°C according to IEC 60947-2 8,38 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,61 / Rating current 45°C according to IEC 60947-2 6,61 / Rating current 5°C according to IEC 60947-2 6,61 / Rating current 5°C according to IEC 60947-2 6,61 / Rating current 5°C accor	Rating current 45°C	5,41 A
Rating current 50°C 5,19 / Rating current 55°C 4,97 / Rating current 60°C 4,74 / Rating current 60°C 4,74 / Rating current 65°C 4,5 / Rating current 0°C 4,24 / Rating current 0°C 4,24 / Rating current 0°C 4,24 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 150°C according to IEC 60947-2 8,17 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current 150°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,8 / Rating current 30°C according to IEC 60947-2 6,8 / Rating current 40°C according to IEC 60947-2 6,8 / Rating current 40°C according to IEC 60947-2 6,8 / Rating current 40°C according to IEC 60947-2 6,8 / Rating current 40°C according to IEC 60947-2 6,8 / R	Rating current 5°C	6,78 A
Rating current 55°C 4,97 / Rating current 60°C 4,74 / Rating current 60°C 4,74 / Rating current 65°C 4,5 / Rating current 70°C 4,24 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,35 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current 20°C according to IEC 60947-2 7,37 / Rating current 20°C according to IEC 60947-2 7,17 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 50°C according to IEC 60947-2 6,81 / Rating current 30°C according to IEC 60947-2 6,81 / Rating current 40°C according to IEC 60947-2 6,81 / Rating current 45°C according to IEC 60947-2 6,21 / Rating current 45°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 6,21 / Rating current 5°C ac	Rating current -5°C	7,07 A
Rating current 60°C 4,74 / Rating current 65°C 4,5 / Rating current 0°C 4,24 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current 10°C according to IEC 60947-2 8,17 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current -15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,8 / Rating current 30°C according to IEC 60947-2 6,8 / Rating current 40°C according to IEC 60947-2 6,8 / Rating current 45°C according to IEC 60947-2 6,8 / Rating current 5°C according to IEC 60947-2 6,8 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 6 /	Rating current 50°C	5,19 A
Rating current 65°C 4,57 Rating current 70°C 4,247 Rating current 0°C according to IEC 60947-2 7,857 Rating current 10°C according to IEC 60947-2 7,857 Rating current 10°C according to IEC 60947-2 7,527 Rating current 10°C according to IEC 60947-2 8,177 Rating current 150°C according to IEC 60947-2 7,357 Rating current 150°C according to IEC 60947-2 8,337 Rating current -15°C according to IEC 60947-2 8,337 Rating current 20°C according to IEC 60947-2 8,487 Rating current 20°C according to IEC 60947-2 8,487 Rating current 25°C according to IEC 60947-2 8,637 Rating current 30°C according to IEC 60947-2 8,637 Rating current 30°C according to IEC 60947-2 6,87 Rating current 30°C according to IEC 60947-2 6,87 Rating current 40°C according to IEC 60947-2 6,87 Rating current 40°C according to IEC 60947-2 6,87 Rating current 45°C according to IEC 60947-2 6,87 Rating current 45°C according to IEC 60947-2 6,217 Rating current 5°C according to IEC 60947-2 7,697 Rating current 5°C according to IEC 60947-2 6,217	Rating current 55°C	4,97 A
Rating current 70°C 4,24 / Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 8,17 / Rating current 10°C according to IEC 60947-2 8,17 / Rating current 10°C according to IEC 60947-2 8,37 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current -15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 35°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,87 / Rating current 30°C according to IEC 60947-2 6,87 / Rating current 35°C according to IEC 60947-2 6,87 / Rating current 40°C according to IEC 60947-2 6,87 / Rating current 5°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 6,21 / Rating current 5°C acco	Rating current 60°C	4,74 A
Rating current 0°C according to IEC 60947-2 7,85 / Rating current 10°C according to IEC 60947-2 7,52 / Rating current -10°C according to IEC 60947-2 8,17 / Rating current 10°C according to IEC 60947-2 8,17 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current 15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,34 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current 20°C according to IEC 60947-2 8,63 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 50°C according to IEC 60947-2 5,74 / <t< td=""><td>Rating current 65°C</td><td>4,5 A</td></t<>	Rating current 65°C	4,5 A
Rating current 10°C according to IEC 60947-2 7,52 / Rating current -10°C according to IEC 60947-2 8,17 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current 150°C according to IEC 60947-2 8,33 / Rating current -15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,48 / Rating current -20°C according to IEC 60947-2 8,48 / Rating current 25°C according to IEC 60947-2 8,63 / Rating current -25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,21 / Rating current 45°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 50°C according to IEC 60947-2 5,74 /	Rating current 70°C	4,24 A
Rating current -10°C according to IEC 60947-2 8,17 / Rating current 150°C according to IEC 60947-2 7,35 / Rating current -15°C according to IEC 60947-2 8,33 / Rating current 20°C according to IEC 60947-2 8,33 / Rating current -20°C according to IEC 60947-2 8,48 / Rating current -20°C according to IEC 60947-2 8,63 / Rating current -25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,61 / Rating current 30°C according to IEC 60947-2 6,87 / Rating current 30°C according to IEC 60947-2 6,81 / Rating current 40°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 6,74 / Rating current 5°C according to IEC 60947-2 6,74 / Rating current 50°C according to IEC 60947-2 5,74 / Rating current 50°C according to IEC 60947-2 5,74 /	Rating current 0°C according to IEC 60947-2	7,85 A
Rating current 150°C according to IEC 60947-2 7,357 Rating current 15°C according to IEC 60947-2 8,337 Rating current 20°C according to IEC 60947-2 7,177 Rating current -20°C according to IEC 60947-2 8,487 Rating current 25°C according to IEC 60947-2 8,487 Rating current 25°C according to IEC 60947-2 8,697 Rating current 35°C according to IEC 60947-2 8,637 Rating current 30°C according to IEC 60947-2 6,87 Rating current 30°C according to IEC 60947-2 6,617 Rating current 40°C according to IEC 60947-2 6,217 Rating current 45°C according to IEC 60947-2 6,217 Rating current 5°C according to IEC 60947-2 7,697 Rating current 5°C according to IEC 60947-2 8,017 Rating current 5°C according to IEC 60947-2 6,747 Rating current 5°C according to IEC 60947-2 6,747 Rating current 5°C according to IEC 60947-2 5,747 Rating current 5°C according to IEC 60947-2 5,747 Rating current 5°C acco	Rating current 10°C according to IEC 60947-2	7,52 A
Rating current -15°C according to IEC 60947-28,33 /Rating current 20°C according to IEC 60947-27,17 /Rating current -20°C according to IEC 60947-28,48 /Rating current -25°C according to IEC 60947-26,99 /Rating current 25°C according to IEC 60947-28,63 /Rating current 30°C according to IEC 60947-28,63 /Rating current 30°C according to IEC 60947-26,8 /Rating current 30°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current 5°C according to IEC 60947-28,01 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Ra	Rating current -10°C according to IEC 60947-2	8,17 A
Rating current 20°C according to IEC 60947-2 7,17 / Rating current -20°C according to IEC 60947-2 8,48 / Rating current 25°C according to IEC 60947-2 6,99 / Rating current -25°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 8,63 / Rating current 30°C according to IEC 60947-2 6,8 / Rating current 35°C according to IEC 60947-2 6,61 / Rating current 40°C according to IEC 60947-2 6,61 / Rating current 45°C according to IEC 60947-2 6,21 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 6 / Rating current 5°C according to IEC 60947-2 6 / Rating current 5°C according to IEC 60947-2 7,69 / Rating current 5°C according to IEC 60947-2 8,01 / Rating current 5°C according to IEC 60947-2 6 / Rating current 5°C according to IEC 60947-2 6 / Rating current 50°C according to IEC 60947-2 5 / Rating current 50°C according to IEC 60947-2 5 / Rating current 60°C according to IEC 60947-2 5 /	Rating current 150°C according to IEC 60947-2	7,35 A
Rating current -20°C according to IEC 60947-28,48 /Rating current 25°C according to IEC 60947-26,99 /Rating current -25°C according to IEC 60947-28,63 /Rating current 30°C according to IEC 60947-26,8 /Rating current 35°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,41 /Rating current 40°C according to IEC 60947-26,41 /Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current 5°C according to IEC 60947-28,01 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25 /Rating current 55°C according to IEC 60947-25 /Rating current 55°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Rating curr	Rating current -15°C according to IEC 60947-2	8,33 A
Rating current 25°C according to IEC 60947-26,99 /Rating current -25°C according to IEC 60947-28,63 /Rating current 30°C according to IEC 60947-26,8 /Rating current 35°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,21 /Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current 5°C according to IEC 60947-28,01 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Stating current 60°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Stating current 60°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Stating current 60°C according to IEC 60947-25 /Rating current 60°C according to IEC 60947-25 /Rating current	Rating current 20°C according to IEC 60947-2	7,17 A
Rating current -25°C according to IEC 60947-28,63 /Rating current 30°C according to IEC 60947-26,8 /Rating current 35°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,41 /Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current -5°C according to IEC 60947-28,01 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-28,01 /Rating current 5°C according to IEC 60947-26 /Rating current 5°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current -20°C according to IEC 60947-2	8,48 A
Rating current 30°C according to IEC 60947-26,8 /Rating current 35°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,41 /Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current -5°C according to IEC 60947-28,01 /Rating current 50°C according to IEC 60947-26 /Rating current 50°C according to IEC 60947-26 /Rating current 55°C according to IEC 60947-26 /Rating current 55°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current 25°C according to IEC 60947-2	6,99 A
Rating current 35°C according to IEC 60947-26,61 /Rating current 40°C according to IEC 60947-26,41 /Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current -5°C according to IEC 60947-28,01 /Rating current 50°C according to IEC 60947-26 /Rating current 50°C according to IEC 60947-26 /Rating current 50°C according to IEC 60947-26 /Rating current 55°C according to IEC 60947-25,74 /Rating current 50°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current -25°C according to IEC 60947-2	8,63 A
Rating current 40°C according to IEC 60947-26,41 /Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current -5°C according to IEC 60947-28,01 /Rating current 50°C according to IEC 60947-26 /Rating current 50°C according to IEC 60947-26 /Rating current 55°C according to IEC 60947-25,74 /Rating current 55°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current 30°C according to IEC 60947-2	6,8 A
Rating current 45°C according to IEC 60947-26,21 /Rating current 5°C according to IEC 60947-27,69 /Rating current -5°C according to IEC 60947-28,01 /Rating current 50°C according to IEC 60947-26 /Rating current 55°C according to IEC 60947-25,74 /Rating current 55°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current 35°C according to IEC 60947-2	6,61 A
Rating current 5°C according to IEC 60947-27,69 /Rating current -5°C according to IEC 60947-28,01 /Rating current 50°C according to IEC 60947-26 /Rating current 55°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current 40°C according to IEC 60947-2	6,41 A
Rating current -5°C according to IEC 60947-28,017Rating current 50°C according to IEC 60947-267Rating current 55°C according to IEC 60947-25,747Rating current 60°C according to IEC 60947-25,487	Rating current 45°C according to IEC 60947-2	6,21 A
Rating current 50°C according to IEC 60947-267Rating current 55°C according to IEC 60947-25,747Rating current 60°C according to IEC 60947-25,487	Rating current 5°C according to IEC 60947-2	7,69 A
Rating current 55°C according to IEC 60947-25,74 /Rating current 60°C according to IEC 60947-25,48 /	Rating current -5°C according to IEC 60947-2	8,01 A
Rating current 60°C according to IEC 60947-2 5,48 /	Rating current 50°C according to IEC 60947-2	6 A
	Rating current 55°C according to IEC 60947-2	5,74 A
Rating current 65°C according to IEC 60947-2 5,19 /	Rating current 60°C according to IEC 60947-2	5,48 A
	Rating current 65°C according to IEC 60947-2	5,19 A

Current correction factors

Correction factor of magnetic tripping with 100 Hz	1,1
Correction factor of magnetic tripping with 200 Hz	1,2
Correction factor of magnetic tripping with 400 Hz	1,5
Correction factor of magnetic tripping with 60 Hz	1,1
Correction factor of rating current for 2 devices placed side-by-side	1
Correction factor of rating current for 3 devices placed side-by-side	0,95
Correction factor of rating current for 4 and 5 devices placed side-by-side	0,9
Correction factor of rating current for 6 devices placed side-by-side	0,85

Power

Power loss per pole at In	1,36 W
Maximum power loss per pole according to the product standard	3 W
Total power loss under IN	5,44 W

Endurance

Electric endurance in number of cycles	4000
Number of mechanical operations	20000

Dimensions

Depth of installed product	70 mm
Height of installed product	83 mm
Width of installed product	70 mm

Installation, mounting

Type of top connection for modular devices	with screw
Tightening torque	2,8Nm
Type of bottom rail clip for modular devices	plastic
Type of top rail clip for modular devices	NA
Type of Bottom Connection for modular devices	Blconnect
Bottom removability for modular devices	yes
Top removability for modular devices	yes
Suitable for flush-mounting	yes

Connection

Upstream cage clamp delivery status	opened
Downstream cage clamp delivery status	opened
Connection cross-section at output with screw, for flexible conductor	1/25 mm²
Connection cross-section of the access with screws, with flexible conductor	1/25 mm²
Connection cross-section at output with screw, for massive conductor	1/35 mm²
Connection cross-section for rigid conductor, upstream terminals with screws	1/35 mm²



Can be accessorized	yes
Standards	
Standard text	EN 60898-1
European directive WEEE	concerned
Safety	
Protection index IP	IP20
Use conditions	
Degree of pollution according to IEC 60664 / IEC 60947-2	2
Class of energy limitation I ² t	3
Altitude	2000 m
Storage temperature	-25 to 80 °C
temperatur	